

FRAMING & WALL UNDERLAY

| Check and Confirm | Check |
|--|-------|
| Framing, as installed, complies with the NZ Building Code or where an existing building that the framing is suitable for the intended building work | |
| Framing has been handled, stored and installed in accordance with manufacturer's or building code specifications | |
| Alignment of framing – i.e. studs and nogs are straight and true, upper framing aligns with lower framing | |
| The flexible or rigid air barrier, as installed, complies with the NZ Building Code or where an existing building that the flexible or rigid air barrier, as installed, is suitable for the intended building work | |
| The flexible or rigid air barrier has been handled, stored and installed in accordance with manufacturers specifications | |

FITTING – BATTENS AND FLASHINGS

| Ensure | Check |
|--|-------|
| 20 mm battens are tacked in place with 40 mm stainless steel clouts or panel pins at 900 mm centres | |
| 45 mm battens are structurally nailed to framing as per JSC Timber details for the appropriate wind zone | |
| All flashings have been fitted correctly and PVC or polyethylene bond break installed as required | |
| Vermin strip extends 10 mm below at the bottom plate | |
| Head flashings are fitted over windows/doors and they extend past the window/door by 30 mm with stop ends | |
| Stop end flashing are installed as per details | |
| Mitred joints are back flashed and fully sealed into place | |
| Building wrap extends over head flashing & is sealed at the lap as per E2/AS1 | |
| Horizontal battens are fixed at all nogs at max 480 mm centres and set out as: Top – 10 mm below horizontal protrusion Bottom – Flush with bottom plate and set back 10 mm from all openings and other battens allowing for vermin strip | |
| Vertical Cavity Battens have $\geq 15^\circ$ degree bevel to the top and bottom ends, sloping down away from the framing | |
| Compliant vermin strip is installed correctly with cavity battens accommodating the flashing and clear off the bottom of the strip | |
| Cavity battens fixed over flashings or flashing tape are trimmed or reduced in thickness to avoid interference with weatherboard position e.g. at the head of a window | |
| For complex junctions such as the inter-storey and meter boxes, check against relevant detailing and specification | |
| No product substitutions of specifically identified and branded products | |

| | |
|---|--|
| | |
| All other products used are supported by information that the products will meet the building code (i.e. comply with Building Act s14G) | |

FIXING CLADDING

| Check and Confirm | Check |
|--|-------|
| All nail fixings pre-drilled at 1 mm diameter smaller than the nail gauge with slight (2°+) upward slope | |
| Setout of the weatherboards allows for a nominal gap of 6-8 mm between the boards | |
| Weatherboards are single face fixed at the centre of the board width | |
| Battens are single face fixed at the centre of batten width through the gap between the boards | |
| For both Board and Batten Where 20 mm battens are used, nails achieve a minimum 30 mm embedment into the framing Where 45 mm structural battens are used, nails achieve a minimum 30 mm embedment into the cavity batten | |
| Nails fixed 30-40 mm above the bottom of the weatherboard, with an upward slope and flush onto the surface | |
| To ensure the nails align vertically across boards | |
| Weatherboards to overhang bottom plate by 50 mm | |
| The bottom of the weatherboards finishes 35 mm clear of finished deck surface, 100 mm clear of paved surfaces, or 175 mm above unsealed ground | |
| Internal and External corners and associated back flashing are installed to JSC installation manual | |
| There is a gap of 5 mm between weatherboards and head flashing | |
| Last weatherboards must have a drip edge as per JSC technical details JVB-XX-01, 01A, 04, 25 & 30 | |

COATING SYSTEM

| Check and Confirm | Check |
|---|-------|
| Factory applied coating is not damaged or contaminated | |
| All cut ends and edges are sealed prior to installation | |
| On-site coats have been applied to coating manufacturer's specifications. | |
| Notify home owner of coating manufacturer's maintenance requirements. | |

NOTE: No product substitutions will be accepted under the JSC Timber system except where otherwise indicated

Email: TechHelp@jsctimber.co.nz

We: www.jsctimber.co.nz

22 Sawmill Road
Riverhead
☎ 09 412 2810

72 Hammersmith Drive
Wigram
☎ 03 348 9726